

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

कार्यालय सहायक यंत्री
लो. स्वा. यौ. उपखण्ड
सरदारपुर, जि. धार (म. प्र.)

No. 252Dated: 10/03/26

It is certified that an inspection team headed by B.L. PARWAR (BLOCK COORDINATOR)
(Name of Officers with designation) from PHED SUB. DIV. SARDARPUR, DIST. DHAR

PHED inspected the **New Talent Public Higher Secondary School, Bhangarh Road, Rajgarh, Tehsil Sardarpur, Dist.- Dhar, MP** on 23/02/2026 and on the basis of Water Test Report (Attached) bearing no. 40 dated 25/02/2026 of SDWTL / PHED / Sardarpur (PHED Lab)

certified that the **New Talent Public Higher Secondary School, Bhangarh Road, Rajgarh, Tehsil Sardarpur, Dist.- Dhar, MP** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 6 month

Signature with seal :-

[Signature]
Assistant Engineer
P.H.E. Sub-Division
Sardarpur, Dist. Dhar

Name :-

:- H.S. BARNIYA

Designation :-

:- ASSISTANT ENGINEERName & address of the office/Department: - PHED SUB DIV. SARDARPUR
DIST - DHAR MP.

To,
New Talent Public Higher Secondary School,
Bhangarh Road, Rajgarh, Tehsil Sardarpur, Dist.- Dhar, MP
(Name and address of the institution)

Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies

[Signature]
सचिव
श्री ईश्वर सिंह तोमर
मेमोरियल एज्युकेशन सोसायटी
धार (म.प्र.)

[Signature]
Principal
New Talent Public
H.S.School, Rajgarh (Dhar)

Sub Divisional Water Testing Laboratory

P.H.E.D. Sardarpur, Dist - Dhar (M.P.)

phelabsardarpur@gmail.com

Water Testing Report

SDWTL/PHED/Sardarpur No:- 40

Date :- 25/02/2026

Ref:- Your Letter No. NTPHS/2025-26/94, Date 23/02/2026

Samples From :- Principal, New Talent Public H.S.,
School, Rajgarh (Dhar).

Date of Receipt :- 23/02/2026

Date of Analysis :- 24/02/2026

(1) R.O. Water

Sample collected and submitted by the customer

S.No.	Parameters	Test Method	BIS 10500:2012 Desirable/ permissible limit and unit	Result
				(1) New Talent P.H.S. School, Rajgarh-R.O. Water
1	Colour	IS 3025 part 4	5/15 Co. Pt Scale	5.0
2	Odour	IS 3025 part 5	Unobjectionable	Unobjectionable
3	Taste	IS 3025 part 8	Unobjectionable	Unobjectionable
4	Turbidity	IS 3025 part 10	1.0/5.0 NTU	0.1
5	pH	IS 3025 part 11	6.5-8.5 pH Scale	6.89
6	Conductivity at 25.0 °C	IS 3025 part 14	Micro mhos/cm	181.6
7	Total Dissolved Solids	By Calculation	500/2000 mg/Lit.	90.2
8	Total Hardness (as CaCO ₃)	IS 3025 part 21	200/600 mg/Lit.	78.4
9	Calcium	IS 3025 part 40	75/200 mg/Lit.	14.0
10	Magnesium	IS 3025 part 46	30/100 mg/Lit.	10.3
11	Sulphate (as SO ₄)	IS 3025 part 24	200/400 mg/Lit.	11.2
12	Total Alkalinity	IS 3025 part 23	200/600 mg/Lit.	8.0
13	Chlorides (as Cl)	IS 3025 part 32	250/1000 mg/Lit.	29.4
14	Fluorides (as F)	IS 3025 part 60	1.0/1.5 mg/Lit.	0.02
15	Nitrates (as NO ₃)	APHA 23 Edition 1500B	45/45 mg/Lit.	—
16	Iron (as Fe)	IS 3025 part 53	1.0/1.0 mg/Lit.	0
17	Manganese	IS 3025 part 59	0.1/0.3 mg/Lit.	0
18	Residual Chlorine	VCM	0.2 mg/Lit. At Consumer point	0
19	Fecal Coliform	APHA 22 Edition 9211B	0/0	0
20	Total Coliform	APHA 22 Edition 9211B	0/0	0
21	Arsenic	IS 3025 Part 37	0.01/0.01	—

Remarks :- (i) Above water Samples testing Result is according by BIS 10500 :2012 and Reaffirmed 2019

(ii) Clear Surrounding the water source
and chlorinate the water.

सचिव

श्री ईश्वर सिंह तोमर

मेमोरियल एज्युकेशन सोसायटी
धार (म.प्र.)

Principal

New Talent Public
H.S.School, Rajgarh (Dhar)

Sub Divisional
CHEMIST

Sub Divisional Water Testing Laboratory

P.H.E Sub Division - Sardarpur